



Surface mounting enclosure, metal, yellow, 1 mounting location



Part no. **M22-11MGE-SAL**  
 Catalog No. **118456**  
 Alternate Catalog No. **M22-11MGE-SALQ**

### Delivery program

Basic function accessories			Surface mounting enclosure
Housing			Metal
			With high-grade steel screws
Number of locations		Qty.	1
<b>Cable entry knockouts</b>			
Cable entry			-
Degree of Protection			IP66
<b>Colour</b>			
Colour			Operator only RAL 1004, yellow Enclosure base RAL 7032, grey
Connection to SmartWire-DT			no
For use with			1 x Ø 22.5
For use with			(Illuminated) pushbuttons (Illuminated) selector switches Key-operated pushbuttons Indicator light controlled stop/emergency-stop buttons with yellow label

### Technical data

<b>General</b>			
Degree of Protection			IP66

### Design verification as per IEC/EN 61439

IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Please enquire
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.

## Technical data ETIM 8.0

Low-voltage industrial components (EG000017) / Enclosure for control circuit devices (EC000200)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Housing for command and alarm devices  
(ecl@ss10.0.1-27-37-12-05 [AKF023014])

Number of command positions			1
Construction type housing			Surface mounting housing
Material housing			Aluminium
Housing material quality			Other
Diameter openings		mm	22.5
Colour housing cover			Yellow
Degree of protection (IP)			IP66
Degree of protection (NEMA)			4X
Width		mm	67
Height		mm	84
Depth		mm	79