



Indicator light, RMQ-Titan, Flush, Without lens

Part no. M22-L-X
216776
EL Number 4355708
(Norway)

| General specifications | | |
|--|--|---|
| Product name | | Eaton Moeller® series M22 Indicator light |
| Part no. | | M22-L-X |
| EAN | | 4015082167769 |
| Product Length/Depth | | 30 millimetre |
| Product height | | 30 millimetre |
| Product width | | 30 millimetre |
| Product weight | | 0.005 kilogram |
| Compliances | | CE Marked |
| Certifications | | CSA Std. C22.2 No. 94-91 EN 60947-5 UL 508 CSA Std. C22.2 No. 14-05 IEC 60947-5 VDE CSA-C22.2 No. 94-91 IEC/EN 60947-5 UL Category Control No.: NKCR CE CSA UL CSA Class No.: 3211-03 VDE 0660 IEC/EN 60947 UL File No.: E29184 CSA File No.: 012528 CSA-C22.2 No. 14-05 |
| Product Tradename | | M22 |
| Product Type | | Indicator light |
| Product Sub Type | | None |
| Catalog Notes | | Lenses for indicator lights → accessories |
| Features & Functions | | |
| Bezel color | | Chrome |
| Bezel material | | Other |
| Design | | Flush |
| Fitted with: | | Front ring |
| Lens color | | Other |
| General information | | |
| Degree of protection | | NEMA 4X, 13 |
| Degree of protection (front side) | | IP67/IP69K |
| Opening diameter | | 22.5 mm |
| Overvoltage category | | III |
| Pollution degree | | 3 |
| Product category | | RMQ-Titan |
| Rated impulse withstand voltage (Uimp) | | 4000 V AC |
| Size | | Front diameter: 29.7 mm |
| Type | | Indicator lights |
| Ambient conditions, mechanical | | |
| Mounting position | | As required |
| Shock resistance | | Mechanical, According to IEC/EN 60068-2-27 30 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms |
| Climatic environmental conditions | | |
| Ambient operating temperature - min | | -25 °C |
| Ambient operating temperature - max | | 70 °C |
| Climatic proofing | | Damp heat, constant, to IEC 60068-2-78 |

| | | |
|--|--|--|
| | | Damp heat, cyclic, to IEC 60068-2-30 |
| Terminal capacities | | |
| Terminal capacity | | 0.5 - 1.5 mm ² , stranded 0.5 - 1.5 mm ² , solid |
| Electrical rating | | |
| Rated insulation voltage (Ui) | | 250 V |
| Communication | | |
| Connection to SmartWire-DT | | Yes With SWD-RMQ connections |
| Contacts | | |
| Force for positive opening - min | | 0 N |
| Design verification | | |
| Equipment heat dissipation, current-dependent Pvid | | 0 W |
| Heat dissipation capacity Pdis | | 0 W |
| Heat dissipation per pole, current-dependent Pvid | | 0 W |
| Rated operational current for specified heat dissipation (In) | | 0 A |
| Static heat dissipation, non-current-dependent Pvs | | 0 W |
| 10.2.2 Corrosion resistance | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | Meets the product standard's requirements. |
| 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | Please enquire |
| 10.2.5 Lifting | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | Meets the product standard's requirements. |
| 10.3 Degree of protection of assemblies | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | Is the panel builder's responsibility. |
| 10.9.2 Power-frequency electric strength | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | Not applicable. |
| 10.11 Short-circuit rating | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 9.0

| | | |
|--|----|------------|
| Low-voltage industrial components (EG000017) / Front element for indicator light (EC000223) | | |
| Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for warning lights (ecl@ss13-27-37-12-11 [AKF029019]) | | |
| Suitable for number of built-in signal lights | | 1 |
| Colour lens | | Other |
| Construction type lens | | Round |
| Hole diameter | mm | 22.5 |
| Width opening | mm | 0 |
| Height opening | mm | 22.5 |
| With front ring | | Yes |
| Material front ring | | Other |
| Colour front ring | | Chrome |
| Type of lens | | Flat |
| Degree of protection (IP), front side | | IP67/IP69K |

