## **DATASHEET - MVS-WB-EM**



## **Reversing wiring kit, for DILEM**

Part no. MVS-WB-EM Catalog No. 220209
Alternate Catalog XTMCXRL No.



**Delivery program** 

Accessories

Description

For use with

Reversing wiring set

Main current wiring for reversing combinations

DILEEM (+MVDILEM)

DILEM12 (+MVDILEM)

DILEM (+MVDILEM)

Instructions The following control cables are integrated in addition to electrical interlock: 0.11: A1 - 0.12: 21

Q11: A1 - Q12: 21 Q11: 21 - Q12: A1 Q11: A2 - Q12: A2

For use with motor protection relay single mounting.

| Design verification as per IEC/EN 61439  |                   |    |  |
|--|-------------------|----|--|
| Technical data for design verification   |                   |    |  |
| Rated operational current for specified heat dissipation   | In                | Α  | 22   |
| Heat dissipation per pole, current-dependent   | P <sub>vid</sub>  | W  | 0.7  |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub>  | W  | 2.1  |
| Static heat dissipation, non-current-dependent   | P <sub>vs</sub>   | W  | 0  |
| Heat dissipation capacity  | P <sub>diss</sub> | W  | 0  |
| Operating ambient temperature min.   |                   | °C | -25  |
| Operating ambient temperature max.   |                   | °C | 50   |
| EC/EN 61439 design verification  |                   |    |  |
| 10.2 Strength of materials and parts   |                   |    |  |
| 10.2.2 Corrosion resistance  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.2Verification of  resistance  of  insulating  materials  to  normal  heat                                       |                   |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                   |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                   |    | Meets the product standard's requirements.   |
| 10.2.5 Lifting   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions  |                   |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances   |                   |    | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections  |                   |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors   |                   |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties   |                   |    |  |
| 10.9.2 Power-frequency electric strength   |                   |    | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage   |                   |    | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material   |                   |    | Is the panel builder's responsibility.   |
| 10.10 Temperature rise   |                   |    | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating   |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must b observed.                                    |
| 10.12 Electromagnetic compatibility  |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function  |                   |    | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

## **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Accessories for low-voltage switch technology (EC002498)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Component for low-voltage switch technology (accessories) (ecl@ss10.0.1-27-37-13-92 [AKN570013])

Type of accessory Connecting bridge

## **Approvals**

| Product Standards                    | IEC/EN 60947-4-1; UL 508; CSA-C22.2 No. 14-05; CE marking |
|--------------------------------------|---|
| UL File No.                          | E36332  |
| UL Category Control No.              | NLRV7   |
| CSA File No.                         | 012528  |
| CSA Class No.                        | 3211-06   |
| North America Certification          | UL listed, CSA certified                                  |
| Specially designed for North America | No  |